



# TEST LOG FOR PERIODIC INSPECTIONS & TESTS FOR HYDRAULIC ELEVATORS

Dept. of Labor & Industries  
 Elevator Section  
 PO Box 44480  
 Olympia, WA 98504-4480

**ASME A17.1 requires periodic tests on various types of elevator equipment. Owner is responsible for all required tests. Some tests may not be applicable; mark them in the appropriate column with "N/A".**  
**Safety test tags are still to be affixed to the appropriate equipment as required by code. A test log is required for each elevator.**  
**Enter test dates (mm/dd) and name of company performing test in the appropriate test column in the year tested.**  
**Include pressure relief setting with date in appropriate column.**

State ID # \_\_\_\_\_

\*Equipment test tags required to be on equipment

Operating Permit Date \_\_\_\_\_

Firefighter's Operation \_\_\_\_\_

Type of Test	1 *Car & Counter-Weight Safeties (When Provided)		2 *Car & Counter-Weight Governors (When Provided)		3 Cylinder Leak Test	4 Terminal Speed Limiting Device	5 Standby Power Operation	6 Flexible Hose Fittings	7 Phase 1 & 2	8 Smoke Detectors	9 Power Door Operation	10 Unexposed Portions of Pistons	11 Pressure Vessels	12 *Oil Buffers (When Provided)		13 Final & Normal Limits	14 Door Closing Force	15 *Relief Valve Setting	16 Door monitoring System	
	Annual	5 Year	Annual	5 Year	Annual	Annual	Annual	Annual	Quarterly	Annual	5 Year	3 Year	3 Year	Annual	5 Year	Annual	Annual	Annual	Annual	
A17.1 Rule	8.11.2.2.2	8.11.2.3.1	8.11.2.2.3	8.11.2.3.2	8.11.3.2.2	8.11.3.2.3h	8.11.3.2.3f	8.11.3.2.4	8.6.10.1	8.11.2.2.6	8.11.2.3.7	8.11.3.3.1	8.11.3.3.2	8.11.2.2.1	8.11.2.3.3	8.11.2.2.5	8.11.2.2.8	8.11.3.2.1	2.26.1.5	
<b>2010</b>																				
<b>2011</b>																				
<b>2012</b>																				
<b>2013</b>																				
<b>2014</b>																				

**Do Not Remove Test Log From Machine Room.  
 Service Maintenance logs must not be used in lieu of this form.**